

Change Order

No. 1

Date of Issuance: _____ Effective Date: _____

Project: Landfill PS Renovation	Owner: City of Crossville TN	Owner's Contract No.:
Contract: CW1 2015-346		Date of Contract: January 5, 2016
Contractor: W & O Construction Co., Inc.		Engineer's Project No.: 3671-09

The Contract Documents are modified as follows upon execution of this Change Order:

Description:

Miscellaneous minor changes at pump station.

Attachments (list documents supporting change):

See attached Change Order Summary

CHANGE IN CONTRACT PRICE:

Original Contract Price:

\$ 379,000.00

[Increase] [Decrease] from previously approved
Change Orders No. _____ to No. _____:

\$ 0.00

Contract Price prior to this Change Order:

\$ 379,000.00

[Increase] [Decrease] of this Change Order:

\$ 9,570.00

Contract Price incorporating this Change Order

\$ 388,570.00

CHANGE IN CONTRACT TIMES:

Original Contract Times: Working days Calendar days

Substantial completion (days or date): 180/July 9, 2016

Ready for final payment (days or date): 180/July 9, 2016

[Increase] [Decrease] from previously approved Change Orders
No. _____ to No. _____:

Substantial completion (days): 0

Ready for final payment (days): 0

Contract Times prior to this Change Order:

Substantial completion (days or date): 180/July 9, 2016

Ready for final payment (days or date): 180/July 9, 2016

[Increase] [Decrease] of this Change Order:

Substantial completion (days or date): 0 days

Ready for final payment (days or date): 0 days

Contract Times with all approved Change Orders:

Substantial completion (days or date): 180/July 9, 2016

Ready for final payment (days or date): 180/July 9, 2016

RECOMMENDED: GRW Engineers

By: Bry S. Lloyd
Engineer (Authorized Signature)

Date: 9 JUNE 16

ACCEPTED: Crossville TN

By: _____
Owner (Authorized Signature)

Date: _____

ACCEPTED: W&O Construction
Co., Inc.

By: R. Oakley
Contractor (Authorized Signature)

Date: 6/10/2016

Approved by Funding Agency (if applicable): _____

Date: _____

Change Order

Instructions

A. GENERAL INFORMATION

This document was developed to provide a uniform format for handling contract changes that affect Contract Price or Contract Times. Changes that have been initiated by a Work Change Directive must be incorporated into a subsequent Change Order if they affect Price or Times.

Changes that affect Contract Price or Contract Times should be promptly covered by a Change Order. The practice of accumulating Change Orders to reduce the administrative burden may lead to unnecessary disputes.

If Milestones have been listed in the Agreement, any effect of a Change Order thereon should be addressed.

For supplemental instructions and minor changes not involving a change in the Contract Price or Contract Times, a Field Order should be used.

B. COMPLETING THE CHANGE ORDER FORM

Engineer normally initiates the form, including a description of the changes involved and attachments based upon documents and proposals submitted by Contractor, or requests from Owner, or both.

Once Engineer has completed and signed the form, all copies should be sent to Owner or Contractor for approval, depending on whether the Change Order is a true order to the Contractor or the formalization of a negotiated agreement for a previously performed change. After approval by one contracting party, all copies should be sent to the other party for approval. Engineer should make distribution of executed copies after approval by both parties.

If a change only applies to price or to times, cross out the part of the tabulation that does not apply.

CHANGE ORDER SUMMARY
CITY OF CROSSVILLE TN
LANDFILL PUMP STATION RENOVATION
CW1 2015-346
Change Order No. 1
GRW Project No. 3671-09

Item No.	Description of Changes	DECREASE in Contract Price	INCREASE in Contract Price
1	Relocate Generator pad to allow access to bypass pump connection.		\$2,441.00
2	Add an air release valve and access manhole to existing forcemain.		\$3,867.00
3	Install new backflow preventor and associated piping.		\$3,262.00
	TOTALS	\$0.00	\$9,570.00
	NET CHANGE IN CONTRACT PRICE		\$9,570.00

Justification:

Miscellaneous changes at pump station.



May 10, 2016

GRW Engineer, Inc.
404 BNA Drive, Suite 201
Nashville, TN 37217
ATTN: Barry Cloyd

RE: City of Crossville Landfill Pump Station Renovation
Change Proposal No. 1

Dear Mr. Burris:

Please see below our proposal for furnishing and installing all material and labor to the following additional work item:

Change Proposal 1:

1. Our price for furnishing all labor, material and equipment required relocating the generator pad to allow for access to the by-pass pump connection, adding a manhole and air relief valve on the new force main pipe and installing a new backflow preventer and associated copper piping to the water line inside the pump station for the lump sum price of Nine Thousand Five Hundred Seventy Dollars and No Cents (\$9,570.00)

Relocate Generator Pad	\$ 2,441.00
Precast Manhole & Air Release Valve	\$ 3,867.00
Backflow Preventer & Copper Pipe	\$ 3,262.00

Should you have any questions please contact me. Thank you for your cooperation in this matter.

Sincerely,

Michael McCarty
Project Manager
W & O Construction Co., Inc.