

CROSSVILLE REGIONAL PLANNING COMMISSION

INSPECTION REPORT

NAME OF SUBDIVISION: The Gardens Phase 8 plat 2 2/11/19
Date

ACTIVITY: Installing Water & Sewer Lines

Road Name(s): Holly Tree Dr.

(subgrade, stone base, final paving).

Approved N/A Unapproved _____ (See remarks)

Water Line Construction:

Approved Unapproved _____ (See remarks)

Water Line Testing:

Approved Unapproved _____ (See remarks)

Hydrant Installation:

Approved Unapproved _____ (See remarks)

Sewer Line Construction: (if applicable)

Approved N/A Unapproved _____ (See remarks)

Remarks:

Water & Sewer line & services have been installed
water has been tested and passed also Bac-Tec have been
been took and passed. sewer line has not been tested
at this time

John Luma
City Engineer or Authorized Representative
County Road Supervisor or Authorized Representative
Manager of Utility District or Authorized Representative