

CITY OF CROSSVILLE  
392 NORTH MAIN STREET  
CROSSVILLE, TENNESSEE 38555~4232  
TEL (931) 456~1830  
(931) 484~5113  
FAX (931) 484~7713

OFFICE OF  
CODES ENFORCEMENT

September 11, 2015

The City of Crossville Codes Enforcement Department went to 40 Carey Road on September 8, 2015 to inspect a manufactured home. The Codes Department found that the manufactured home had been altered by adding a front and rear porch roof system that is being supported by the manufactured home roof system. The roof system on a manufactured home is an engineer design that is only designed for wind and snow load. When a manufactured home is altered from its intended design, a structural engineer must design the alterations of the structure. Therefore the City of Crossville Codes Department **does not recommend** that this manufactured home be allowed to be brought in and used for a single family dwelling in the City of Crossville.

Sincerely,



Jeff Kerley  
Building Official  
City of Crossville