

**CROSSVILLE REGIONAL PLANNING COMMISSION
INSPECTION REPORT**

DATE: 6/4/2025

NAME OF SUBDIVISION OR SITE PLAN: Peach Tree Dr.

ACTIVITY: Installing Approx. 800 ft of 6" Waterline with Blow Off & Fire Hydrant 4-water services

Road Names (including lengths):

(☐ subgrade, ☐ stone base, ☐ binder paving)

For Final, Has the top coat payment been made?

Approved ☐ Unapproved ☐ (See remarks)

Water Line Construction, Size: 6" Material: PVC

Approved ☒ Unapproved ☐ (See remarks)

Hydrant Installation:

Approved ☒ Unapproved ☐ (See remarks)

Sewer Line Construction, Type: _____ Size: _____

Approved ☐ Unapproved ☐ (See remarks)

Storm Water Structure(s), Type: _____

Approved ☐ Unapproved ☐ (See remarks)

Remarks: Waiting of Bac-Tec before Approving water Line
Test Passed 6/3/2025. Air Release needs a traffic Rated Box
not installed Yet. Bac-Tec came back good water was
turn on 6/9/2025

Tom Lunn

City Engineer or Authorized Representative
County Road Supervisor or Authorized Representative
Manager of Utility District or Authorized Representative