

City of Crossville

392 North Main Street
Crossville, Tennessee 38555-4232
Tel (931) 456-1830
(931) 484-5113
Fax (931) 484-7713

Office of
Codes Enforcement


Reference: 627 Cook Rd, Crossville TN. 38555

Chelsey Hall: Applicant
Permit/Project # 2022-303

Manufactured Home: HUD Tag #'s GEO 1006569 & GEO 1006570
Date of Manufacture: 1997

Codes department has reviewed the subject manufactured home and found it to be without any visible structural issues. There are some life safety items which need addressed: No smoke detectors, Electrical outlets damaged and some hanging out of the wall, and the water heater is not designed for a manufactured home.

Codes department can support a variance based on the age being greater than 20 years. All other ordinance requirements too be completed and all safety items addressed prior to final inspection and occupancy.



Danny Thurman
Building Official