

City of Crossville

392 North Main Street
Crossville, Tennessee 38555-4232
Tel (931) 456-1830
(931) 484-5113
Fax (931) 484-7713


Office of
Codes Enforcement

June 14, 2019

To Whom It May Concern:

On June 13, codes department reviewed a manufactured home for Mr. Thomas Baker at his property off Sparta Dr. Based on the decal on the unit it was manufactured in 1997, HUD Tag # TRA393237, SL # MS B 98 1680 SN35412. The unit has metal siding with varying degrees of indentations, has a metal roof which has multiple patched spots. Based on the manufactures information the unit was manufactured for climate zone 1 which is the southern climate, Georgia, Florida etc.

Based on the age, and exterior condition codes department cannot recommend a variance be issued.

A handwritten signature in black ink, appearing to read "Danny Thurman", with a long, sweeping horizontal stroke extending to the right.

Danny Thurman

Director of Codes