

CROSSVILLE REGIONAL PLANNING COMMISSION

INSPECTION REPORT

NAME OF SUBDIVISION: The Gardens Phase VI USE11/25/15
Date

ACTIVITY:

Road Construction: N/A (subgrade, stone base, final paving).Approved / Unapproved / (See remarks)

Water Line Construction:

Approved ✓ Unapproved / (See remarks)

Water Line Testing:

Approved ✓ Unapproved / (See remarks)Date Approved 11/16/15 & 11/17/15

Hydrant Installation:

Approved ✓ Unapproved / (See remarks)

Sewer Line Construction: (if applicable)

N/AApproved / Unapproved / (See remarks)

Remarks: Hicks Excavation will be responsible for any freezing or breaks
on the water service lines due to them not being back filled on the side
where the 4" sewer will be going. Back-T Test was good for use.
Have not received a copy of test at this point but Billy Martin said
if it had not passed they would have let him know by now.

Tom Turner

City Engineer or Authorized Representative
 County Road Supervisor or Authorized Representative
 Manager of Utility District or Authorized Representative