



## Legislation Details (With Text)

**File #:** 21-0075      **Version:** 1      **Name:** Miller Avenue Sewer Line Close-out Change Order  
**Type:** Contract      **Status:** Passed  
**File created:** 3/18/2021      **In control:** City Council  
**On agenda:** 4/13/2021      **Final action:** 4/13/2021  
**Title:** Approval of Miller Avenue Sewer Line Close-out Change Order  
**Sponsors:** Engineering Department, Tim Begley  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. Closeout Change Order

Date	Ver.	Action By	Action	Result
4/13/2021	1	City Council	approved as recommended	Pass
4/6/2021	1	Work Session	recommended for approval	

### Approval of Miller Avenue Sewer Line Close-out Change Order

**SUMMARY:** The close-out change order is attached with an increase of \$47,519.00 in contract price. Major items for the over run are the linear footage of Ditch Crossings and the linear footage of 12" DR11 HDPE.

The Ditch Crossings were designed during a dry season and the contract was performed in a wet period; therefore, more rock was required for the crossings making the footage increase.

The additional footage of 12" DR11 HDPE is because the project was extended to the new portion of the line installed with the Lantana Road Project.

The Director of Engineering recommends the approval of the change order.

**BUDGET ACCOUNT:**

**NECESSARY COUNCIL ACTION:** Approve Close-out Change Order in the amount of \$47,519.00.