



Legislation Details (With Text)

File #: 19-0110 **Version:** 1 **Name:** Pine Ridge Pump Station
Type: Bids/Purchases **Status:** Passed
File created: 3/28/2019 **In control:** City Council
On agenda: 4/9/2019 **Final action:** 4/9/2019
Title: Approval to purchase check valve replacement-Pine Ridge Pump Station
Sponsors:
Indexes:
Code sections:
Attachments: 1. SU-175 Crossville Pine Ridge L.S. Check Valve Replacements

Date	Ver.	Action By	Action	Result
4/9/2019	1	City Council	approved as recommended	Pass
4/2/2019	1	Work Session		

Approval to purchase check valve replacement-Pine Ridge Pump Station

SUMMARY: Veolia requests to purchase a check valve replacement in the amount of \$5,845.75 from Wascon to include materials and labor. Wascon is a sole source provider for this product. This purchase will prevent future pump/shaft failure.

BUDGET ACCOUNT:413-41920-260

NECESSARY COUNCIL ACTION: Approve purchase