



Legislation Details (With Text)

File #: 15-0311 **Version:** 1 **Name:** Flood Damage on UV System at WWTP
Type: Ordinance **Status:** Adopted
File created: 7/16/2015 **In control:** City Council
On agenda: 9/10/2015 **Final action:** 9/10/2015
Title: Ordinance amending the FY2015-16 budget for UV System Flood Damage repairs
Sponsors: Waste Water Treatment Plant
Indexes: Budget Amendment Required
Code sections:
Attachments: 1. ENAQUA quote, 2. UV budget amendment

Date	Ver.	Action By	Action	Result
9/10/2015	1	City Council	adopted on third reading	Pass
8/13/2015	1	City Council	approved on second reading	Pass
7/23/2015	1	Call for Special Meeting	approved on first reading	Pass

Ordinance amending the FY2015-16 budget for UV System Flood Damage repairs

SUMMARY: On July, 2-3, Crossville got just under 5 inches of rainfall. Water entered the wastewater plant in the area where the UV system is located. This area flooded, doing major damage to the UV system. A quote was received from ENAQUA in the amount of \$50,225.82 for the needed repairs. An insurance claim has been filed.

BUDGET ACCOUNT: Budget Amendment required

NECESSARY COUNCIL ACTION: Approve budget amendment.