



## Legislation Details (With Text)

**File #:** 20-0270      **Version:** 1      **Name:** Miller Avenue Sewer Line Change Order  
**Type:** Contract      **Status:** Passed  
**File created:** 9/22/2020      **In control:** City Council  
**On agenda:** 10/13/2020      **Final action:** 10/13/2020  
**Title:** Approval of Miller Avenue Sewer Line Change Order  
**Sponsors:** Engineering Department, Tim Begley  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. Change Order

Date	Ver.	Action By	Action	Result
10/13/2020	1	City Council	approved as recommended	
10/6/2020	1	Work Session		

### Approval of Miller Avenue Sewer Line Change Order

**SUMMARY:** The contractor has exposed the existing casing under Miller Avenue. The casing is a 16 inch casing and the outside diameter of the new sewer force main is 13.2 inches which leaves an 1.4 inch even space between the two pipes. Spacers cannot be installed in this small area and we do not want to install the line with out spacers because the sewer line could be deeply scratched when installed and cause future breaks.

The Contractor, Engineer and City Staff have decided that it is in the best long-term interest of the City to rebores Miller Avenue with a new casing for the new sewer line. This eliminates the need for the temporary bypass and loading of the existing casing as shown on the attached Change Order 1. The Director of Engineering recommends the approval of the attached change order in the amount of \$10,750.

### BUDGET ACCOUNT:

**NECESSARY COUNCIL ACTION:** Discuss the approval of the Change Order.