



## Legislation Details (With Text)

**File #:** 12-0391      **Version:** 1      **Name:** Peachtree Drive Water Line Extension  
**Type:** Contract      **Status:** Passed  
**File created:** 11/6/2012      **In control:** City Council  
**On agenda:** 11/13/2012      **Final action:** 11/13/2012  
**Title:** Approval of Peachtree Drive Waterline Extension variance  
**Sponsors:** Engineering Department, Tim Begley  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. City code 18-108, 2. Peachtree Drive map

Date	Ver.	Action By	Action	Result
11/13/2012	1	City Council	approved as recommended	

### Approval of Peachtree Drive Waterline Extension variance

**SUMMARY:** A property owner has requested that the City extend a waterline on Peachtree Drive to his property. The property owner has agreed to pay for the materials as required in the City code. A six inch line exists on Camelia Drive and Magnolia Lane which intersect Peachtree Drive as shown on the attached drawing.

Staff has reviewed the request and has determined that a two inch line is more than adequate for domestic water needs on this section of Peachtree Drive. Fire flow can be obtained on the adjacent streets and will meet the current subdivision regulations. Staff is requesting a variance pursuant to the Crossville City Code 18-108 that the extension be installed as a two inch line instead of a six inch line per the City Code.

**BUDGET ACCOUNT:** 413-52140-400

**NECESSARY COUNCIL ACTION:** Approve the variance from a six inch line to a two inch line.