



## Legislation Details (With Text)

---

**File #:** 23-0240      **Version:** 2      **Name:** Goose Pointe Sewer Extension  
**Type:** Resolution      **Status:** Passed  
**File created:** 7/14/2023      **In control:** City Council  
**On agenda:** 8/8/2023      **Final action:** 8/8/2023  
**Title:** Approval of Goose Pointe Sewer Extension (Deer Creek Subdivision)  
**Sponsors:** Planning Commission  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. Cost Estimate\_Goose Pointe LPS Extension, 2. Location Map Goose Pointe Sewer Extension

Date	Ver.	Action By	Action	Result
8/8/2023	2	City Council	approved as recommended	Pass
8/1/2023	2	Work Session	recommended for approval	
7/20/2023	1	Planning Commission	recommended for approval	Pass

### Approval of Goose Pointe Sewer Extension (Deer Creek Subdivision)

**SUMMARY:** The property owner of Lot 8 on Goose Pointe has requested a mainline sewer extension to their property. It is approximately 185 feet. The City engineering staff is recommending a 2-inch low pressure sewer line. The cost estimate for material is \$738.98, which includes all materials and the TDEC fee. The property owner has requested the city to install the line. The property owner will need to pay the City of Crossville a total of \$6,812.98 to have the sewer line extended. That total includes the sewer tap, grinder pump and the cost estimate. Attached is the cost estimate and location map. Planning Commission has suggested approval for the sewer line extension. Staff recommends the approval of the mainline sewer extension to lot 8 of Goose Pointe.

**NECESSARY COUNCIL ACTION:** Approve the mainline extension.