



Legislation Details (With Text)

File #: 21-0006 **Version:** 1 **Name:** Limitations on Discharge Strength
Type: Ordinance **Status:** Adopted
File created: 12/29/2020 **In control:** City Council
On agenda: 4/13/2021 **Final action:** 4/13/2021
Title: Ordinance amending Table 1, Title 18: Water and Sewers
Sponsors:
Indexes:
Code sections:
Attachments: 1. Title 18 Table 1

Date	Ver.	Action By	Action	Result
4/13/2021	1	City Council	adopted on third reading	
3/9/2021	1	City Council	approved on second reading	
2/9/2021	1	City Council	approved on first reading	
2/2/2021	1	Work Session	recommended for approval	

Ordinance amending Table 1, Title 18: Water and Sewers

SUMMARY: The Wastewater Department has requested an amendment to the pH level on Table 1 of the Limitations on Discharge Strength; changing it from 6.0-9.0 to 5.5--9.5; therefore, requiring an ordinance amendment. TDEC approves the modification.

BUDGET ACCOUNT:

NECESSARY COUNCIL ACTION: Approve ordinance