



City of Crossville

392 North Main Street
Crossville, Tennessee 38555

Legislation Text

File #: 13-0032, **Version:** 1

Matters relative to old landfill pump station

SUMMARY: This is a main sewer collection system drainage basin pump station. The pump station has two pumps. One pump is down and currently being rebuilt (parts are ordered). This is a 75 HP dry pit stand pump. This area serves approximately one third of the sewer collection system and is in a high risk area due to I & I in the sewer collection system. The estimated cost is \$30,000.

BUDGET ACCOUNT: 413-52230-940-008

NECESSARY COUNCIL ACTION: Approval to bid