



City of Crossville

392 North Main Street
Crossville, Tennessee 38555

Legislation Text

File #: 19-0407, **Version:** 1

Ordinance amending FY19-20 Budget for Palace Theater Repairs

SUMMARY: The Palace Theater is leaking in several locations. It's been determined that the majority, if not all of the leaks are from the mortar joints in the masonry walls. The estimated cost of the construction is \$50,000. A budget amendment is recommended in the amount of \$65,000 which will include minor roof repairs and engineering.

BUDGET ACCOUNT: 110-44500-930-001 Debit Misc Imp-Palace
 110-27100 Credit Net Position

NECESSARY COUNCIL ACTION: Approve budget amendment