



City of Crossville

392 North Main Street
Crossville, Tennessee 38555

Legislation Text

File #: 21-0006, **Version:** 1

Ordinance amending Table 1, Title 18: Water and Sewers

SUMMARY: The Wastewater Department has requested an amendment to the pH level on Table 1 of the Limitations on Discharge Strength; changing it from 6.0-9.0 to 5.5--9.5; therefore, requiring an ordinance amendment. TDEC approves the modification.

BUDGET ACCOUNT:

NECESSARY COUNCIL ACTION: Approve ordinance