



City of Crossville

392 North Main Street
Crossville, Tennessee 38555

Legislation Text

File #: 19-0110, **Version:** 1

Approval to purchase check valve replacement-Pine Ridge Pump Station

SUMMARY: Veolia requests to purchase a check valve replacement in the amount of \$5,845.75 from Wascon to include materials and labor. Wascon is a sole source provider for this product. This purchase will prevent future pump/shaft failure.

BUDGET ACCOUNT:413-41920-260

NECESSARY COUNCIL ACTION: Approve purchase