



City of Crossville

392 North Main Street
Crossville, Tennessee 38555

Legislation Text

File #: 15-0311, **Version:** 1

Ordinance amending the FY2015-16 budget for UV System Flood Damage repairs

SUMMARY: On July, 2-3, Crossville got just under 5 inches of rainfall. Water entered the wastewater plant in the area where the UV system is located. This area flooded, doing major damage to the UV system. A quote was received from ENAQUA in the amount of \$50,225.82 for the needed repairs. An insurance claim has been filed.

BUDGET ACCOUNT: Budget Amendment required

NECESSARY COUNCIL ACTION: Approve budget amendment.