



City of Crossville

392 North Main Street
Crossville, Tennessee 38555

Legislation Text

File #: 22-0313, **Version:** 1

Approval of MIOX Cell Rehabilitation

SUMMARY: The cell for the MIOX machine for the Holiday Hills Water Plant is out of service. MIOX has provided a quote to rebuild the cell in the amount of \$12,780. Staff recommends rebuilding rather than replacing due to the cost to replace being twice as much.

BUDGET ACCOUNT: 413-52130-930-004

NECESSARY COUNCIL ACTION: Approve purchase