



# City of Crossville

392 North Main Street  
Crossville, Tennessee 38555

## Legislation Text

---

**File #:** 20-0202, **Version:** 2

---

### Action on water loss

**SUMMARY:** City Manager Greg Wood and City Engineer Tim Begley said installing master meters at the Meadow Park Lake facility, which would include check valves to accurately read the amount of water being pumped, would give a more accurate computation on how much water is actually being pumped out. Utility Maintenance Supervisor Billy Martin said that replacing individual meters will also give more accurate readings.

Mr. Wood asked for Council permission to bid out the master meters for Meadow Park Lake. If given, a budget amendment will be required once the bids are received.

### BUDGET ACCOUNT:

**NECESSARY COUNCIL ACTION:** Authorize bid for master meters for MPL plant