



# City of Crossville

392 North Main Street  
Crossville, Tennessee 38555

## Legislation Text

---

**File #:** 23-0240, **Version:** 2

---

### Approval of Goose Pointe Sewer Extension (Deer Creek Subdivision)

**SUMMARY:** The property owner of Lot 8 on Goose Pointe has requested a mainline sewer extension to their property. It is approximately 185 feet. The City engineering staff is recommending a 2-inch low pressure sewer line. The cost estimate for material is \$738.98, which includes all materials and the TDEC fee. The property owner has requested the city to install the line. The property owner will need to pay the City of Crossville a total of \$6,812.98 to have the sewer line extended. That total includes the sewer tap, grinder pump and the cost estimate. Attached is the cost estimate and location map. Planning Commission has suggested approval for the sewer line extension. Staff recommends the approval of the mainline sewer extension to lot 8 of Goose Pointe.

**NECESSARY COUNCIL ACTION:** Approve the mainline extension.