



City of Crossville

392 North Main Street
Crossville, Tennessee 38555

Legislation Text

File #: 15-0204, **Version:** 1

Discussion and action on Downtown Waterline Project Change Order

SUMMARY: The Contractor has offered a \$40,000.00 deduct to the project if he is allowed to change the depth of the waterline to have a minimum cover of 3 feet. The project was bid at depths of over 7 feet to allow for future storm sewer and minimum depths for the relocation of overhead lines. A recommendation from the Engineer will be available at the meeting.

BUDGET ACCOUNT:

NECESSARY COUNCIL ACTION: Approve change order, contingent on TDOT's approval and accordingly with the Engineer's recommendation.